

TEST CERTIFICATE

489 1305 124A

in observance with EN 489:2009

for

elbow for district heating pre-insulated pipeline systems

“Salling Plast 90° Flex-Elbow“

by order of

Salling Plast A/S, 96821 Ranum, Denmark

Test sample No. 3722:

pre-insulated elbow “Salling Plast 90° Flex-Elbow”

standard size DN 80/160

Test report 1127E5072

The following tests have been completed in observance with the European Standard

EN 489:2009 at the FFI for one elbow in April 2013:

Soil stress test and water impermeability test.

The 90° Flex-Elbow has passed the tests successfully.


Hemmingen, 2013-05-30



Dipl.-Ing. Thomas Grage
Managing Director



Max-von-Laue-Str. 23
30966 Hemmingen
+49 511 94370 0
www.fernwaerme.de



Dipl.-Ing. (FH) Volker Herbst
Project Manager